



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

February 22, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-010/01T-0
ER 100450 FILE 841-23
PLA- 1539

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-010/01T-0. This event was determined to be reportable per Technical Specification 6.9.1.8.1, in that runout flow on the feedwater pumps was determined to be in excess of the maximum value assumed in the FSAR transient analysis.

H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/cg

Attachment

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8303010611 830222
PDR ADOCK 05000387
S PDR

Ier