

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 C I A D I C I F I 1 2 0 0 1 0 0 0 0 0 0 1 0 0 3 4 1 1 1 1 4 1 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 34

CONT

01 L 6 0 1 5 0 0 0 2 7 5 7 0 1 1 3 8 3 8 0 2 1 4 8 3 3

REPORT SOURCE 30 31 DOCKET NUMBER 35 36 EVENT DATE 37 38 REPORT DATE 39 40

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (19)

02 Prior to fuel load, the Liquid Radwaste Effluent Flow Recorder (FR-20) was

03 discovered to be inoperable during the discharge of the contents of a tank in

04 the Liquid Radwaste System. FR-20 is required to be operable by Technical

05 Specification 3.3.3.9. All Technical Specification Action Statements were

06 satisfied and no radioactive effluents were released. This event was in

07 no way affected public health and safety. Reportable per Technical

08 Specification section 6.9.1.13.b.

09

SYSTEM CODE M C 11 CAUSE CODE E 12 CAUSE SUBCODE E 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE T 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 8 3 EVENT YEAR 8 3 SEQUENTIAL REPORT NO. 0 2 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN E 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 0 0 ATTACHMENT SUBMITTED N 23 NRC-4 FORM 315 N 24 PRIME COMP. SUPPLIER L 25 COMPONENT MANUFACTURER B 0 8 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Failure of FR-20 was caused by an out of tolerance flow transmitter

11 (FT-243) which was cleaned and adjusted and returned to service.

12

13

14

15 FACILITY STATUS B 28 % POWER 0 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 NA AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 0 0 0 0 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED DESCRIPTION NA 44

8303010635 830214
PDR ADOCK 05000275
S PDR

NAME OF PREPARER William J. Kelly PHONE: 805/595-7351

NRC USE ONLY