



Certified By

mal

Public Service Electric and Gas Company P.O. Box E Hancocks Bridge, New Jersey 08038

Salem Generating Station

February 25, 1983

Mr. R. C. Haynes
Regional Administrator
USNRC
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Haynes:

REPORTABLE OCCURRENCE 83-011/01P
SALEM NO. 1 UNIT LER

This letter is to confirm our verbal report to the NRC Headquarters on Friday, February 25, 1983, advising of a potential reportable occurrence in accordance with Technical Specifications, Section 5.9.1.8.a.

At 0021 hours, February 25, 1983, during routine power operation, the Reactor Trip Breakers failed to open in response to a reactor trip signal caused by low-low water level in No. 12 Steam Generator. The reactor was manually tripped immediately by the control operator and currently the unit is being maintained in Mode 3.

An investigation is in progress, and a detailed report will be submitted within the 14 day time period as required by the Technical Specifications.

Sincerely yours,

H. J. Midura
General Manager -
Salem Operations

FD:ks

CC: Distribution

8303010680 830225
PDR ADOCK 05000272
S PDR