

CONTROL BLOCK:

1	2	3	4	5
---	---	---	---	---

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	G A E I H I										2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5												
7	8	LICENSEE CODE										14	LICENSE NUMBER										25	LICENSE TYPE										30	CAT										58

CON'T

0	↑	REPORT SOURCE																										
7	8	L	6	0	5	0	0	0	3	2	1	7	0	6	1	7	3	2	8	0	2	2	2	8	3	9		
		60	61	DOCKET NUMBER										68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On June 17, 1982, with Unit One in startup, at 100 MWt, while performing
03 surveillance of the "HYDROGEN AND OXYGEN ANALYZER INSTRUMENTS", the "B"
04 H2 and O2 analyzer was discovered to be out of calibration. T.S.3.7.A.
05 6.d required a 7-day LCO if one H2 O2 analyzer is inoperable. The "A"
06 H2 O2 system was operable. Plant operation was not affected. The health
07 and safety of the public were not affected by this repetitive event as
08 last reported on LER 50-366/1982-003.

SYSTEM CODE P B 11		CAUSE CODE X 12		CAUSE SUBCODE Z 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE E 15		VALVE SUBCODE Z 16							
EVENT YEAR 8 2		SEQUENTIAL REPORT NO. 0 5 8		OCCURRENCE CODE 0 3		REPORT TYPE X		REVISION NO. 1									
ACTION TAKEN E 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. N 24		PRIME COMP. SUPPLIER A 25		COMPONENT MANUFACTURER H 1 2 5 26	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this event has been attributed to instrument drift. The

1 1 "B" hydrogen and oxygen analyzer was recalibrated, as required by the

1 2 surveillance procedure, and immediately returned to service. A design

1 3 change request has been written to replace the "A" and "B" hydrogen and

1 4 oxygen analyzer systems.

8 9 30 32

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 5 C 28 0 0 4 29 NA B 31 Performing Normal Surveillance

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z (33) Z (34) NA

7 8 9 10 11

AMOUNT OF ACTIVITY (35)

NA

45 80

LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION (39)						
1	7	0	0	0	(37)	Z	(38)	NA		

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
		NA	

7	8	9	11	12	80
LOSS OF OR DAMAGE TO FACILITY (43)					
TYPE		DESCRIPTION			
1	9	2	(42)	NA	

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (45) 8303080048 830222
2 0 [N] (44) NA S PDR ADOCK 05000321 PDR NRC USE ONLY
7 8 9 10 68 69 80

NAME OF PREPARER S. B. Tipps

PHONE (912) 367-7851