



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

February 23, 1983

Mr. R. W. Starostecki, Director
U.S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim 30-day report in accordance with 10CFR50.55(e) for the potentially reportable deficiency concerning separation criteria for Power Generation Control Complex (PGCC) equipment. This condition was reported via telephone to Mr. J. Wiggins of your staff on January 20, 1983 as a potentially reportable deficiency.

Very truly yours,

S. F. Manno
Vice President
Nuclear Construction

Enclosure
cc: Director of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. R. D. Schultz, Resident Inspector

IE27

Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station - Unit 2
Docket No. 50-410

Interim Report for a Potential
50.55(e) Concerning Separation
Criteria for Power Generation Control Complex (PGCC) Equipment

While Niagara Mohawk Quality Assurance was reviewing separation criteria for Power Generation Control Complex (PGCC) equipment supplied by General Electric, it was discovered that notes concerning separation criteria which appear on the system elementary diagrams were not transferred to the corresponding connection diagrams and thus, were not incorporated into the PGCC hardware.

The impact of this deficiency on the hardware has not yet been determined.

General Electric has been notified of this deficiency through issuance of Nonconformance Report No. 53.

A final report will be submitted by April 1, 1983.