



Donald A. Wells
Manager Quality Assurance
(313) 237-9657

2000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000

February 18, 1983

EF2-62,079

Mr. James G. Keppler
Regional Administrator
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Enrico Fermi Power Plant, Unit 2
USNRC Licensing Docket: 50-341
USNRC IE Bulletin 82-04 (12-3-'82)

Subject: Detroit Edison Response to NRC IE Bulletin 82-04

Dear Mr. Keppler:

In response to the subject bulletin request, we hereby submit the following report.

The Project Engineering Organization (PEO) for the Enrico Fermi Power Plant, Unit 2, has reviewed the unit's safety-related systems for any applications of the electrical penetration described in the subject Bulletin. None of the electrical penetration assemblies, installed or planned for installation in safety-related systems at the Fermi 2 Plant, are supplied by Bunker Ramo. A comparison survey was performed of the nozzles provided in the containment vessel versus all the electrical penetration assemblies specified. The Fermi 2 Plant uses electrical containment penetrations manufactured by Conax Corporation exclusively. This letter constitutes the Company's final report on IE Bulletin 82-04.

Should you require additional information from Detroit Edison in this matter, please advise us.

Very truly yours,

DAW/JDR/sb

8303080072 830218
PDR ADOCK 05000341
Q PDR

MAR 3 1983

IE 11

Mr. James G. Keppler
Page 2

February 18, 1983
EF2-62,079

cc: Director
Division of Reactor Construction Inspection
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Bruce Little, Resident Inspector
U. S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 North Dixie Highway
Newport, Michigan 48166

Mr. M. D. Lynch
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555