

CONTROL BLOCK:

--	--	--	--	--	--

 ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 1 2 5 8 3 3 0 2 2 4 8 3 9

50 51 DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 80

02 DURING NORMAL OPERATIONS, REPAIRS TO THE #2 B.A. TRANSFER PUMP WERE BEING

03 PERFORMED WHEN THE #1 B.A. TRANSFER PUMP HAD TO BE REMOVED FROM SERVICE DUE TO

04 EXCESSIVE SEAL LEAKAGE. THIS CONDITION WAS NONCONSERVATIVE PER T.S. 3.1.2.6.

05 ACTION REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. THIS

05 WAS THE FIRST OCCURRENCE OF THIS TYPE.

07 _____

03 _____

SYSTEM CODE P I C 11		CAUSE CODE E 12		CAUSE SUBCODE B 13		COMPONENT CODE P U M P X I 14				COMP. SUBCODE B 15		VALVE SUBCODE Z 16					
EVENT YEAR 8 3 21 22		SEQUENTIAL REPORT NO. 0 1 1 23 24 25 26		OCCURRENCE CODE 0 3 27 28 29		REPORT TYPE L 30 31		REVISION NO. 0 32									
ACTION TAKEN A 33		FUTURE ACTION Z 34		EFFECT ON PLANT Z 35		SHUTDOWN METHOD Z 36		HOURS 0 0 0 0 37 38 39 40		ATTACHMENT SUBMITTED N 41		NPRD-4 FORM SUB. N 42		PRIME COMP. SUPPLIER N 43		COMPONENT MANUFACTURER G 2 0 0 44 45 46 47	

113 DURING SEAL REPLACEMENT OF THE #2 B.A. TRANSFER PUMP, THE #1 B.A. TRANSFER PUMP HAD,

TO BE REMOVED FROM SERVICE DUE TO A BEARING FAILURE. THE BEARING FAILURE ON THE #1

113 PUMP PROPAGATED THE SEAL LEAKAGE. THE #2 PUMP WAS DECLARED OPERABLE WITHIN THE

13 J.T.S. TIME LIMIT. DUE TO THE HARSH APPLICATION ENCOUNTERED BY THESE PUMPS,

1 4 OCCASIONAL REPAIRS CANNOT BE TOTALLY AVOIDED.

8 9
FACILITY STATUS (E) (28) % POWER (1) (0) (0) (29) OTHER STATUS (30) NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
METHOD OF DISCOVERY (A) (31) OPERATOR OBSERVATION (32)
45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
ACTIVITY CONTENT
RELEASED OF RELEASE (Z) (33) (Z) (34) NA AMOUNT OF ACTIVITY (35)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
LOCATION OF RELEASE (36)
45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
PERSONNEL EXPOSURES
NUMBER (0) (0) (0) (37) TYPE (Z) (38) DESCRIPTION (39) NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
PERSONNEL INJURIES
NUMBER (0) (0) (0) (40) DESCRIPTION (41)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
LOCS OF OR DAMAGE TO FACILITY
TYPE (Z) (42) DESCRIPTION (43) NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
PUBLICITY
ISSUED DESCRIPTION (44) NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
NRC USE ONLY

8303080087 830224
PDR ADOCK 05000315
S PDR

8303080087 830224
PDR ADOCK 05000315
S PDR

NRC USE ONLY

NAME OF PREPARER

PAUL CARTEAUX

PHCNE

616-465-5901