

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 WIKNP1 200-000000-00 341111 4 5
7 8 9 14 15 25 26 30 57 CAT 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

01 L 605000305 7012683 8022583 9
7 8 60 61 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During full power operation the 1A Diesel Generator was taken out of service to repair
03 leaks in the diesel generator cooling system's heat exchanger. This placed the plant
04 in an LCO per TS 3.7.b(2) and is reportable per TS 6.9.2.b(2) as operation permitted
05 by an LCO. Since the redundant diesel generator was operable there was no effect on
06 public safety or plant operation.
07

08 09
7 8 9
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
EE E D HTEXCH C Z
9 10 11 12 13 18 19 20
 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
83 002 03 L 0
21 22 23 24 26 27 28 29 30 31 32
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
B Z Z Z 0000 N Y X Y021
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The tube leaking was due to corrosion on the service water side of the cooling water
11 heat exchanger. Two of the tubes were plugged and Belzona Molecular Metal was applied
12 to all four tube sheet faces. As a retest, the diesel was run for 1 hour and no leaks
13 were found.
14

15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
E 100 NA A Operator Observed High Cooling Water
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
Z Z NA NA Level
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
000 Z NA
 PERSONNEL INJURIES NUMBER DESCRIPTION
000 NA
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
Z NA
 PUBLICITY ISSUED DESCRIPTION
N NA

8303080134 830225
 PDR ADCK 05000305
 S PDR

NRC USE ONLY

NAME OF PREPARER S.L. Bernhoft

PHONE (414) 388-2560, Ext. 340