

**LICENSEE EVENT REPORT**

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	J	S	G	S	2	2	c	o	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9						14	15	25										26	30				57	CAT	58		
		LICENSEE CODE								LICENSE NUMBER											LICENSE TYPE								

CON'T

0 1  
7 8

REPORT SOURCE L 6 0 5 0 0 0 3 1 1 7 0 1 3 1 8 3 8 0 2 2 3 8 3 9  
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On January 18, 1983, during routine operation, the Diesel Generator Area Low Pressure

0 3 | CO2 System automatic initiation feature was disabled and tagged out for planned

0 4 | maintenance. The tagout was necessary to insure personnel safety during work in the

0 5 | area. With the feature inoperable, Action Statement 3.7.10.3a applied. Due to

0 6 | continuing work in the area projected during the upcoming refueling outage, the system

0 7 | was left disabled. After 14 days, the event required a special report in accordance

0 8 | with Technical Specification 6.9.2f.

7 8 9

0 9		SYSTEM CODE A B		11	CAUSE CODE X		12	CAUSE SUBCODE Z		13	COMPONENT CODE I N S T R U				14	COMP. SUBCODE C		15	VALVE SUBCODE Z		16		
7	8	9	10		11	12		13						14		15		16					
17		LER/RO REPORT NUMBER		EVENT YEAR 8 3		21	22	SEQUENTIAL REPORT NO. 0 0 8		24	25	26	OCCURRENCE CODE 9 9		28	29	REPORT TYPE X		30	31	REVISION NO. 0		32
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		22	ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER						
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	
X	18	X	19	Z	20	Z	21	0	0	0	0	Y	23	N	24	A	25	C	1	2	5	26	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The CO2 manual actuation capability was maintained. A continuous fire watch with  
1 1 backup fire suppression equipment was immediately established in the area, in  
1 2 compliance with the action statement. The measures will be in effect until  
1 3 completion of the refueling.  
1 4

FACILITY STATUS (28) 1 5 E 7 8 9  
 % POWER (29) 0 5 5 10 12 13  
 OTHER STATUS (30) NA 44  
 METHOD OF DISCOVERY (31) A 45 46  
 DISCOVERY DESCRIPTION (32) Planned Maintenance 80  
 ACTIVITY CONTENT RELEASED OF RELEASE (33) 1 6 Z 7 8 9  
 AMOUNT OF ACTIVITY (35) Z 10 11 12 13  
 LOCATION OF RELEASE (36) NA 45 46 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	2	(38)	NA	(39)

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

LOSS OF OR DAMAGE TO FACILITY (43)  
TYPE DESCRIPTION  
1 9 2 (42) NA  
7 8 9 10

PUBLICITY  
 ISSUED DESCRIPTION (45)  
 2 0 N (44) NA  
 7 8 9 10

8303090225 830224  
 PDR ADOCK 05000311  
 S PDR

NRC USE ONLY  
 68 69 80

NAME OF PREPARER

R. Frahm

**PHONE:**

(609) 935-6000 Ext. 3078

07007 10000