

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

B. RAY
STATION MANAGER

March 2, 1983

RECEIVED
NRC

1983 MAR -4 AM 10:21

SCE

REGION V

TELEPHONE
(714) 492-7100

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 83-014
San Onofre Nuclear Generating Station, Unit 2

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating License NPF-10 for San Onofre, Unit 2, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) form for an occurrence involving Limiting Condition for Operation (LCO) 3.1.3.1 associated with the Control Element Assemblies (CEA's). Enclosed LER 83-014 addresses this event, including corrective actions and measures to prevent recurrence.

If there are any questions regarding the above, please contact me.

Sincerely,



Enclosure: LER 83-014

cc: A.E. Chaffee (USNRC Resident Inspector, San Onofre, Units 2 and 3)
R.J. Pate (USNRC Resident Inspector, San Onofre, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Office of Management Information and Program Control (MIPC)

Institute of Nuclear Power Operations (INPO)

8303110115 830302
PDR ADOCK 05000361
S PDR

IE-22
83-93

ATTACHMENT TO LER 83-014

SOUTHERN CALIFORNIA EDISON COMPANY
SAN ONOFRE NUCLEAR GENERATING STATION

UNIT NO. 2, DOCKET NO. 50-361

SUPPLEMENTAL INFORMATION FOR EVENT DESCRIPTION:

Following slippage of CEA 79 at 1456 and entrance into LCO 3.1.3.1, Action Statement 'c', actions were immediately initiated to return the inoperable CEA to operable status within one hour. Additionally, the shutdown margin was verified to be greater than 5.15% delta k/k. After the slippage of CEA 86 at 1523, LCO 3.1.3.1, Action Statement 'b', was also invoked. The shutdown margin was again verified. Action Statement 'b' was exited at 1531, but Action Statement 'c' was still applicable. The plant was taken to Mode 3 at 1542, thus exiting Action Statement 'c'.