

## LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER					25	26	LICENSE TYPE					30	37	38	39			

CONT

0	1	L	6	0	5	0	0	0	3	1	6	7	0	2	0	3	8	3	3	0	3	0	2	8	3	9
7	8	REPORT SOURCE		50	51	DOCKET NUMBER					55	59	EVENT DATE					74	75	REPORT DATE					80	

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 DURING NORMAL OPERATIONS, FIRE DOOR #374, TO THE START-UP BLOWDOWN FLASH TANK AREA,  
0 3 WOULD NOT CLOSE ON TWO SEPARATE OCCASIONS. THIS CONSTITUTED AN INOPERABLE PENETRA-  
0 4 TION FIRE BARRIER, NONCONSERVATIVE WITH RESPECT TO T.S. 3.7.10. ACTION REQUIREMENTS  
0 5 WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS OCCURRENCE: 82-067

0 6  
0 7  
0 8

0	9	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP SUBCODE		VALVE SUBCODE		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.			
7	8	A	B	11	E	12	B	13	X	X	X	X	X	X	14	Z	15	Z	16	18	3	0	2	5	0	3	L	0
LERIRO REPORT NUMBER		17		21		22		23		24		25		26		27		28		29		30		31		32		
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRO-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER												
A		Z		Z		Z		0		N		N		A		X												
33		34		35		36		37		40		41		42		43		44		45		46		47				

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 3 ON 2/3/83 FIRE DOOR 374 WAS UNABLE TO CLOSE AGAINST AIR FLOW THROUGH DOOR OPENING.  
1 4 THE DOOR CLOSER MECHANISM WAS REPLACED AND THE DOOR OPERATED SATISFACTORILY. HOWEVER  
1 5 ON 2/5/83, WINDS SUBSIDED AND THE CLOSER SHUT THE DOOR ABRUPTLY, CAUSING THE CLOSER  
1 6 ARM TO BECOME DISENGAGED. THE CLOSER ARM AND SCREWS WERE REPLACED, THE DOOR CLOSER  
1 7 WAS ADJUSTED TO AN INTERMEDIATE SETTING AND THE DOOR OPERATED SATISFACTORILY.

1	5	E	28	1	0	0	29	NA	30	B	31	OPERATOR OBSERVATION					32
7	8	FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION					30		
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		35		NA		LOCATION OF RELEASE					36		
1	6	Z	33	Z	34	NA	44	NA	45						30		
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION		39		NA					30		
1	7	0	10	0	37	Z	38						30				
PERSONNEL INJURIES		NUMBER		DESCRIPTION		41		NA					30				
1	8	0	10	0	40						30						
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION		43		NA					30				
1	9	Z	42						30								
PUBLICATION		ISSUED DESCRIPTION		45		NA					30						
2	10	N	44						30								

8303140525 830302  
PDR AD0CK 05000316  
S PDR

NRC USE ONLY

NAME OF PREPARER

PAUL CARTEAUX

PHONE:

616-465-5901