

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY
STATION MANAGER

February 28, 1983

RECEIVED
NRC

83 MAR -3 PM 12:39

SCE

REGIONAL

TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-362
Prompt Report
Licensee Event Report No. 83-005
San Onofre Nuclear Generating Station, Unit 3

Pursuant to Section 6.9.1.12.b of Appendix A, Technical Specifications to Operating License NPF-15 for San Onofre Unit 3, this submittal provides the written confirmation of our February 25, 1983 prompt notification to the NRC of a reportable occurrence involving the snubbers in two Reactor Coolant sample lines: one capable of being isolated by Containment Isolation Valve 3HV508 and the other capable of being isolated by Containment Isolation Valve 3HV517.

On February 22, 1983, while Unit 3 was in Mode 5, loose snubbers and hangers in two sampling lines of the Reactor Coolant loops were observed by a Station engineer. We have been unable to determine when, since the last surveillance (October 1982), the snubbers and hangers were loosened. However, since the components may have been loosened prior to entry into Mode 4 on January 5, 1983 and Limiting Conditions for Operation (LCO's) 3.7.6 "Snubbers" and 3.6.3 "Containment Isolation Valves", are applicable in Modes 1 through 4, the prompt notification of February 25, 1983 was made.

8303110239 830228
PDR ADOCK 05000362
S PDR


IE-22
83-91

February 28, 1983

Investigation to determine the cause, the corrective actions to be taken, and measures to prevent recurrence of this event are continuing. Licensee Event Report (LER) No. 83-005 will address this event and will be submitted by March 11, 1983.

If there are any questions regarding the above, please contact me.

Sincerely,

A handwritten signature in dark ink, appearing to read 'R. H. Engelken', with a stylized, cursive script.

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Units 2 & 3)

R. J. Pate (USNRC Resident Inspector, San Onofre Units 2 & 3)