

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY
STATION MANAGER

February 22, 1983

RECEIVED
NRC

1983 FEB 24 PM 12:31

SCE

REGION V 103

TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
Prompt Report
Licensee Event Report No. 83-018
San Onofre Nuclear Generating Station, Unit 2


Pursuant to Appendix A Technical Specification 6.9.1.12.b and .i to Operating License NPF-10 for San Onofre, Unit 2, this submittal provides the written confirmation of our prompt notification to the NRC on February 18, 1983, of a reportable occurrence involving plant vent stack effluent monitoring instrumentation.

With both Units 2 and 3 shut down in Mode 5 and common vent stack monitor 2/3RT-7808 removed from service for modification, wide range monitor 3RT-7865-1 was discovered to be inoperable.

A 14-day followup report and copy of Licensee Event Report (LER) 82-018 will be submitted by March 4, 1983.

If there are any questions, please contact me.

Sincerely,



cc: A.E. Chaffee (UNSRC Resident Inspector, San Onofre, Units 2 and 3)
R.J. Pate (USNRC Resident Inspector, San Onofre, Units 2 and 3)

8303110258 830222
PDR ADOCK 05000361
S PDR

IE-22
83-80