

CONTROL BLOCK:

							(1)
--	--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5				
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58			59

CCN'T

REPORT SOURCE 01 L 6 0 5 0 - 0 3 2 4 7 0 1 2 6 8 3 8 0 2 2 5 8 3 9

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During plant operation, while performing the operability test of the RHR Service

0 3 | Water System loop A, PT-08.1.4.a, it was discovered that the A RHR heat exchanger

0 4 | service water outlet FCV, 2-E11-F068A, could not be opened using the RTGB controller.

0 5 | At the time of this event, the B PHR service water loop was operable. This event

0 6 | did not affect the health and safety of the public.

0 7 |

0 8 |

7 8 9 |

Technical Specifications 3.7.1.1, 6.9.1.9b

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22		
		W	B	E		X		V	A	L	V	O	P	A	Z		
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38		
		8	3	0	1	8	0	3	L	0							
ACTION TAKEN		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54		
X	Z	Z		Z		0	0	0	0	N		Y	N	L	2	0	0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A loose mechanical coupler in the valve position modulator circuit feedback

1 1 | potentiometer prevented the valve operator, Model No. SMB-00, from opening the

1 2 | valve. The coupler was fastened using Loc-tite and the valve was satisfactorily

1 3 | operated as per the PT. This is an isolated reportable event, therefore no further

1 4 | action regarding this event is planned.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	0	8	0	NA	B	Periodic Test	
7	8	9	10	11	12	13	14	15	16
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	Z	NA	NA				
7	8	9	10	11	12	13	14	15	16
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	Z	NA				
7	8	9	10	11	12	13	14	15	16
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	NA					
7	8	9	10	11	12	13	14	15	16
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	NA						
7	8	9	10	11	12	13	14	15	16
PUBLICITY		ISSUED		DESCRIPTION					
2	0	N	8303140567 830225	PDR AT CK 05000324					
7	8	9	10	11	12	13	14	15	16
								NRC USE ONLY	

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521