

Public Service
Electric and Gas
Company

Thomas J. Martin
Vice President
Engineering and Construction

80 Park Plaza, Newark, NJ 07101 201-430-8316 Mailing Address: P.O. Box 570, Newark, NJ 07101

March 3, 1983

50-354
-355

Mr. R. C. Haynes, Administrator
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region 1
631 Park Avenue
King of Prussia, PA 19406

Dear Mr. Hayes:


NRC IE BULLETIN NO. 82-04
DEFICIENCIES IN PRIMARY CONTAINMENT
ELECTRICAL PENETRATION ASSEMBLIES
HOPE CREEK GENERATING STATION

In reply to IE Bulletin No. 82-04, dated December 3, 1982,
we report the following:

IE Bulletin No. 82-04 addresses a significant problem
with electrical connections in electrical penetration
assemblies supplied by Bunker Ramo Corporation of
Chatsworth, California.

Hope Creek Generating Station uses only Westinghouse
electrical penetration assemblies. Therefore, NRC IE
Bulletin 82-04 is not applicable to Hope Creek.

Very truly yours,



CC: Office of Inspection and Enforcement
Division of Reactor Construction - Inspection
Washington, D.C.

NRC Resident Inspector - Hope Creek
P.O. Box 241
Hancocks Bridge, NJ 08038

8303140574 830303
PDR ADOCK 05000354
G PDR

IEH