

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1750 Chestnut Street Tower II

83 MAR 7 AIO: 5

March 4, 1983

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street, NW  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-259/83007

The enclosed report provides details concerning unidentified leakage  
exceeding 5 gpm following a reactor scram. This report is submitted  
in accordance with Browns Ferry unit 1 Technical Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*H. J. Green*

H. J. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

OFFICIAL COPY

8303140601 830304  
PDR ADDCK 05000259  
S PDR

1983-TVA 50TH ANNIVERSARY

An Equal Opportunity Employer

TE 22