

## LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 1 2 0 0 - 0 0 0 0 0 0 - d d 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

01 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 1 1 0 9 8 2 8 0 3 0 2 8 3 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 DURING NORMAL OPERATION, THE UNIT 2 AUXILIARY CABLE VAULT (ZONE 11) EXPERIENCED AN  
03 INADVERTANT CO<sub>2</sub> DISCHARGE (REF: 50-316/82-092). AFTER DETERMINING THAT THE CO<sub>2</sub>  
04 ACTUATION WAS SPURIOUS, THE CO<sub>2</sub> TANK WAS ISOLATED AT 1512 HOURS TO TERMINATE THE  
05 DISCHARGE. THE MAIN ISOLATION VALVE WAS USED WHICH ALSO ISOLATED UNIT 1. THIS  
06 EVENT WAS NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICATION 3.3.3.8.  
07 PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.

08

09 SYSTEM CODE A B 11 CAUSE CODE X 12 CAUSE SUBCODE E 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE E 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
17 LER/RO REPORT NUMBER 8 2 21 22 23 24 25 26 27 28 29 30 31 32  
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
H 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25 P 4 3 5 26  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 THE CO<sub>2</sub> TANK MAIN ISOLATION WAS ISOLATED WHICH AFFECTS BOTH UNIT 1 AND 2. APPROX-  
11 IMATELY 18 MINUTES LATER, THE VALVE ISOLATING THE SPECIFIC AREA OF CONCERN WAS  
12 CLOSED AND THE MAIN ISOLATION RE-OPENED. AN OPERATING MEMO WAS ISSUED WHICH  
13 DESCRIBES THE PREFERRED METHOD OF ISOLATION AND DISCOURAGES USE OF THE TANK'S MAIN  
14 ISOLATION VALVE. NO FURTHER ACTION PLANNED.

15 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION QA SURVEILLANCE 32  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 PERSONNEL EXPOSURES NUMBER 0 0 9 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

18 PERSONNEL INJURIES NUMBER 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

19 LOSS OF OR DAMAGE TO FACILITY TYPE 42 DESCRIPTION NA 43  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER

D. F. KRAUSE

PHONE (616) 465-5901 ext.1097

8303140610 830302  
PDR ADOCK 05000315  
S PDR