



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 2, 1983

83 MAR 8

AD: 20

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Fire Rated
Floor Penetrations in the
Auxiliary Building Opened
LER 82-150/99 X-1
AECM-83/0139

This letter submits an update to a previous report submitted on December 28, 1982. The event for which the report was submitted occurred on November 22, 1982, when five fire-rated door penetrations in the Auxiliary Building were open to route cable as required by a design change package. A Limiting Condition for Operation was entered in accordance with Technical Specification 3.7.7. The report was submitted as a Special Report pursuant to Technical Specification 3.7.7.

The work being performed under Design Change Package 82-4145 is not complete. Attached is LER 82-150/99 X-1, which is an interim report.

Yours truly,


FOR J. P. McGaughy, JR

JPM:sap
Attachment

cc: (See Next Page)

8303150146 830302
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0139

Page 2

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555