

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M S G G S 1 2 0 0 - 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 4 1 6 7 1 1 2 2 8 2 8 0 3 0 2 8 3 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On November 22, 1982, an LCO was entered in accordance with T.S.3.7 an five
0 3 fire-rated floor penetrations in the Auxiliary Building we The penetrations
0 4 were opened to route cable as required by Design Change (DCP) 82-4145. The
0 5 event had no effect on the health and safety of ne did not constitute a
0 6 threat to plant safety. This report is submit Special Report pursuant to
0 7 T.S.3.7.7.
0 8

0 9 SYSTEM CODE A H 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE X X X X X X 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 8 2 21 1 5 0 24 9 9 28 9 30 1 32
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN X 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NRPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 DCP 82-4145 was issued to complete the heat tracing portion of the Drywell
1 1 Monitoring System and required cable routing through the penetrations. A fire
1 2 watch was established on November 22, 1982, in accordance with T.S.3.7.7. Work is
1 3 continuing on the heat tracing. This is an interim report. A follow-up report
1 4 will be submitted by May 1, 1983.

1 5 FACILITY STATUS B 28 % POWER 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Planned Activity 32
7 8 9 10 12 13 44 45 46 80
1 6 ACTIVITY CONTENT RELEASED Z 33 OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 44 45 80
1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 11 12 13 80
1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 11 12 80
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 80
2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 80
8303150183 830302
PDR ADOCK 05000416
S PDR
NRC USE ONLY
68 69 80