

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	J	S	G	S	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4					5
2	5	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58	

CON'T

REPORT SOURCE 01 60 61 0 5 0 0 0 3 1 1 7 68 69 0 2 0 3 8 3 74 75 8 0 3 0 3 8 3 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On February 3, 1983, during routine shutdown operation, analysis of a sample of the Reactor Coolant System (RCS) boron concentration revealed that the concentration was slightly less than required by the Technical Specifications. Action Statement 3.9.1 was entered, all core alterations and positive reactivity additions were immediately suspended, and boration of the RCS was immediately performed to restore the concentration to within specification. The event constituted operation in a degraded mode in accordance with Technical Specification 6.9.1.9.b.

09		SYSTEM CODE C B		CAUSE CODE C	CAUSE SUBCODE Z	COMPONENT CODE Z Z Z Z Z Z						COMP. SUBCODE Z	VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16					17
LER RO REPORT NUMBER		EVENT YEAR 8 3			SEQUENTIAL REPORT NO. 0 0 9			OCCURRENCE CODE 0 3		REPORT TYPE L			REVISION NO. 0	
21	22	23	24	25	26	27	28	29	30	31	32			
ACTION TAKEN X	FUTURE ACTION Z	EFFECT ON PLANT Z	SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED Y		NPRD-4 FORM SUB. N		PRIME COMP. SUPPLIER Z		COMPONENT MANUFACTURER Z 9 9 9	
33	34	35	36	37	38	39	40	41	42	43	44 45 46 47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Hydrolazing of the steam generators was in progress. Boron sampling frequency had

1 1 been increased; periodic RCS boration was being performed to maintain concentration.

1 2 Samples immediately prior to the event were in specification, results were within

1 3 sample error of specification. No procedural problems were apparent.

1 4

8 9
FACILITY STATUS (1) 5 (H) (28) % POWER (0) (0) (0) (29) OTHER STATUS (30) NA
7 8 9 10 11 12 13 44 45 46 80
ACTIVITY CONTENT
RELEASED OF RELEASE (1) 6 (Z) (33) (Z) (34) NA AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80
PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (37) (Z) (38) NA
7 8 9 11 12 13 90
PERSONNEL INJURIES
NUMBER DESCRIPTION (40) NA
7 8 9 11 12 80
LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION (42) NA
7 8 9 10 12 80
PUBLICITY
ISSUED DESCRIPTION (44) NA
7 8 9 10 80
8303140245 830304
PDR ADOCK 05000311
S PDR
NRC USE ONLY
68 69 80

NAME OF PREPARER

R. Frahm

PHONE:

(609) 935-6000 Ext. 3078

047-028