



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER
Vice President

February 17, 1983

TELEPHONE
AREA CODE 716 546-2700

Mr. Ronald C. Haynes, Regional Administrator
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: I&E Inspection Report 82-24
Notice of Violation
Failure to Post Firewatch and Failure to Perform
Surveillance Test Within Test Frequency
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. Haynes:

On February 7, 1983 Mr. R. P. Zimmerman brought to our attention that our initial response on Inspection Report 82-24 omitted a description of those actions we plan to take to improve the effectiveness of our management control systems governing the performance of plant modifications. This letter supplements our letter dated January 27, 1983 on the same subject.

In January of 1983, we implemented a program of modification follow at Ginna. This program utilizes the resources of ten station engineers each being assigned approximately five modification projects.

In addition, modification follow groups under the direction of these station engineers are currently being organized. These modification follow groups include, as applicable, members from operations, maintenance, testing, quality control, health physics and training. The responsibilities of these groups include:

- 1) Design review for compatibility with existing systems, operability and maintainability
- 2) Construction procedure preparation and review
- 3) Construction sequence following
- 4) Preparation/change to plant procedures for operation and maintenance
- 5) Pre-operational and startup testing
- 6) Training of applicable station personnel.

DATE February 17, 1983
TO Mr. Ronald C. Haynes


It is hoped that the implementation of this program will greatly improve the effectiveness of Ginna Station to integrate plant modification activities with normal maintenance and operation.

Very truly yours,


John E. Maier

JEM/lms

Subscribed and sworn to me
on this 17th day of February 1983



RICHARD F. LAITENBERGER
Notary Public State of New York
Monroe County, N.Y.
Commission Expires March 30, 19 83
Reg. No. 2235125