


Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

ROBERT DIETCH
VICE PRESIDENT

March 8, 1983

TELEPHONE
213-572-4144

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

As requested, this letter provides our response for San Onofre Units 2 and 3 to IE Bulletin No. 83-01: Failure of Reactor Trip Breakers (Westinghouse DB-50) to Open on Automatic Trip signal.

Westinghouse Model No. DB-50 reactor trip circuit breakers are not installed at San Onofre Units 2 and 3. General Electric Model No. AK-2-25 reactor trip circuit breakers are used which are configured such that either the automatic or manual trip signal will actuate both the undervoltage and shunt relays. Thus, diversity and redundancy are provided within each AK-2-25 circuit breaker. In addition, preventative maintenance is performed in accordance with Item 3 of IE Bulletin 79-09: Failures of GE Type AK-2 Circuit Breakers in Safety Related Systems, to assure breaker design performance. The startup preventative maintenance program was reviewed and accepted by the NRC as documented in NRC Inspection Report No. 50-361/81-07, and the station preventative maintenance program has been reviewed and revised to be

IE11

Mr. R. H. Engelken

-2-

March 8, 1983

SCE

identical to the startup program in the areas identified in Item 3 of IE Bulletin 79-09. Therefore, San Onofre Units 2 and 3 are not affected by IE Bulletin 83-01.

Subscribed on this 8th day of March, 1983.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By:

Robert Dietch
Robert Dietch
Vice President

Subscribed and sworn to before me this
8th day of March 1983.

Agnes Crabtree
Notary Public in and for the County of
Los Angeles, State of California

My Commission Expires: Aug 27, 1986

cc: Document Control Desk, NRC
(Washington D. C.) (Original)
A. E. Chaffee, USNRC
Site Inspector, S023

