



Wisconsin Electric POWER COMPANY

231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

March 9, 1983

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. NUCLEAR REGULATORY COMMISSION
Washington, D. C. 20555

Attention: Mr. R. A. Clark, Chief
Operating Reactors Branch 3

Gentlemen:

DOCKET NOS. 50-266 AND 50-301
MODIFICATION OF TECHNICAL SPECIFICATION
CHANGE REQUEST NO. 69
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

On July 2, 1981 Wisconsin Electric Power Company, Licensee for the Point Beach Nuclear Plant, Units 1 and 2, submitted a license amendments application to incorporate certain changes into the Point Beach Nuclear Plant Technical Specifications which would permit repair of degraded or defective steam generator tubes by sleeving. The NRC staff requested that this license amendments application be modified to include limits on reactor coolant activity similar to those limits contained in the standard technical specification. Accordingly, we have included herewith revised pages for Section 15.3.1.C, "Maximum Coolant Activity", and Table 15.4.1-2, "Minimum Frequencies for Equipment and Sampling Tests", of the Point Beach Technical Specifications. Specific changes on each page are identified by margin bars.

In accordance with the Commission's regulations, we have enclosed three signed originals and 40 copies of this modification to our license amendments application. We understand that your review of this matter has been otherwise completed and the license amendments will be issued in the near future.

8303150333 830309
PDR ADOCK 05000266
P PDR

Very truly yours,

Vice President - Nuclear Power

C. W. Fay

Enclosures

Copy to NRC Resident Inspector

Subscribed and sworn to before me
this 9th day of March 1983.

Carolley Pleischmann
Notary Public, State of Wisconsin
My Commission expires July 1, 1984.

A001