

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M D C C N 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 7 7 0 1 2 7 8 3 8 0 2 2 5 8 3 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 1538, during normal operation, intake structure door IS-1 was
0 3 found open (T.S. 3.7.10). Security personnel shut the door at
0 4 1645.
0 5 Similar events: none.
0 6
0 7
0 8

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
Z Z 11 A 12 C 13 Z Z Z Z Z Z 14 Z 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RQ REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 3 0 0 6 0 3 L 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOUR ATTACHMENT SUBMITTED NRPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
Z 18 H 19 Z 20 Z 21 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 On 1/27/83 the subject intake structure watertight door was painted.
1 1 Personnel did not inform the control room that the door would be open
1 2 for an extended period of time in accordance with instructions posted
1 3 on the door. The associated personnel will be counseled concerning
1 4 adherence to posted instructions.
7 8 9 80

1 5 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
E 28 1 0 0 29 N/A A 31 Security Observation
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 N/A N/A
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
0 0 0 37 Z 38 N/A
7 8 9 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
0 0 0 40 N/A
7 8 9 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 N/A
7 8 9 10 80

2 0 PUBLICITY ISSUED DESCRIPTION (45)
N 44 N/A
7 8 9 10 80

8303140378 830225
PDR ADOCK 05000317
S PDR

NRC USE ONLY

NAME OF PREPARER J. S. Lagiewski/C. R. Mahon

PHONE (301) 269-4747/4867