



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi NRC REGION II

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 2, 1983

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

83 MAR 7 AIO: 58

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Inoperable
Fire Door
LER 82-120/99 X-1
AECM-83/0142

This letter submits an update to a previous report submitted on December 13, 1982. The event for which the report was submitted occurred on November 5, 1982, when fire door 1A106 was opened in order to drain Standby Service Water Loop B. The event was reported pursuant to Technical Specification 3.7.7.a.

All corrective action is complete (the door has been restored). Attached is LER 82-120/99 X-1.

Yours truly,


FOR J.P. McGaughy JR.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

8303140403 830302
PDR ADDCK 05000416
FDR
5

OFFICIAL COPY

IE 22