



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

February 28, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-020/03L-0
ER 100450 FILE 841-23
PLA-1552

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-020/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the Control Structure Chlorine Detector "A" was inoperable. Similar Licensee Event Reports are: 82-025, 82-053, 82-073 and 83-008.

H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/cg

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

IE22