



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 1, 1983

JAMES P. MCGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

83 MAR 8 AID - 20

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Update Report - Inoperable  
Fire Doors  
LER 82-095/99 X-1  
AECM-83/0136

This letter submits an update to a previous report submitted on December 13, 1982. The event for which the report was submitted occurred November 6, 1982, when three fire-rated doors in the Auxiliary Building were blocked open to route sandblasting hoses into the suppression pool. The condition was reported by Special Report in accordance with Technical Specification 3.7.7.

All corrective action is now complete. Attached is LER 82-095/99 X-1, which is a final report.

Yours truly,

*[Signature]*  
FOR J.P. McGaughy, Jr.

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8303150443 830301  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22