

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 PASES 1200-000000-000341111145  
7 8 9 14 15 25 26 30 37 38 58

CONT

01 REPORT SOURCE L605000387701298380228839  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During the Startup Test Program, on January 29, 1983, and February 3, 1983,

03 the Control Structure Chlorine Detector "A" was declared inoperable due to a

04 failure of the constant drip feature. This is reportable under Technical

05 Specification 6.9.1.9.b. There were no adverse consequences in that the

06 redundant detector was operable and no chlorine spill occurred.

07

08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
S G 11 B 12 A 13 INSTRU 14 E 15 Z 16

17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
8 3 020 03 L 0

21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER 26  
X 18 F 19 Z 20 Z 21 0000 N 23 N 24 A 25 W 025 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 In both instances, the working fluid crystallized on the detector wick and

11 orifice, clogging the orifice. The wick and orifice were cleaned and the

12 detector returned to service. The applicable surveillance procedure has been

13 revised and approved to inspect the detector on a more frequent basis. Engin-

14 eering evaluation of the problem is continuing.

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32  
B 28 04829 n/a A 31 operator observation

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
Z 33 Z 34 n/a n/a

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  
000 37 Z 38 n/a

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41  
000 40 n/a

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43  
Z 42 n/a

20 PUBLICITY ISSUED DESCRIPTION 45  
N 44

8303140412 830228  
PDR ADOCK 05000387  
S PDR

NRC USE ONLY

NAME OF PREPARER L.A. Kuczynski

PHONE: (717) 542-2181 X3240