

NAME: _____


UPDATE REPORT-PREVIOUS REPORT DATE 10/11/78
LER 78-031 Revision 1
Omaha Public Power District
Fort Calhoun Station Unit No. 1
Docket No. 05000285

Attachment No. 1

Safety Analysis

The plant instrument system is so designed that no single failure can prevent the safe shutdown of the plant if required. During the time the "D" channel hot leg RTD was inoperable, the remaining hot leg temperature indications were operable.

All hot leg RTD's will continue to be checked by visual inspection.

A handwritten signature in dark ink, appearing to read "H. Anderson", is located in the lower right quadrant of the page.

UPDATE REPORT-PREVIOUS REPORT DATE 10/11/78
LER 78-031 Revision 1.
Omaha Public Power District
Fort Calhoun Station Unit No. 1
Docket No. 05000285

Attachment No. 2

Failure Data

This is the first failure resulting from water in the pothead at the
Fort Calhoun Station Unit No. 1.

Re Andrews