

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201
January 25, 1983
QA-2231

E. A. BORGMANN
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler
REGIONAL ADMINISTRATOR

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT I
I.E. INSPECTION REPORT 82-01, ITEM 3A (5)
DOCKET NO. 50-358, CONSTRUCTION PERMIT NO.
CPPR-88, W.O. #57300 JOB E-5590 FILE NO. NRC-1

Gentlemen:

This letter constitutes a supplement to our previous responses dated August 4, 1982 and QA-2193 dated January 4, 1983 concerning the subject Report.


The latter of the above responses stated that verification of cable grip installation for vertical runs of cable over thirty-five (35) feet would be verified when installed in conduit. The letter should also have included vertical cable tray risers.

In addition, delays associated with the S&L approval of DDC E-8112 have postponed the expected completion date of the effort to February 28, 1983. Therefore, cable grip installation will be verified for cable installed on vertical cable risers and vertical conduit greater than 35 feet by February 28, 1983.

We trust the above will be found acceptable as a supplement response to the subject report.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 
E. A. BORGMANN
SENIOR VICE PRESIDENT

FKP:as

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
Attn: W. F. Christenson
Zimmer Project Inspector
Region III

8305240012 830520
PDR ADOCK 05000358
Q PDR

FEB 3 1983