


THE CINCINNATI GAS & ELECTRIC COMPANY

WM. H. ZIMMER NUCLEAR POWER STATION UNIT 1  
P.O. BOX 201, MOSCOW, OH 45153



CINCINNATI, OHIO 45201

February 23, 1983  
QA-2274

E. A. BORGMANN  
SENIOR VICE PRESIDENT

U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Attention: Mr. J. G. Keppler  
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT 1  
I.E. INSPECTION REPORT 82-01  
ITEM 3a(5) CABLE GRIP INSTALLATIONS  
DOCKET NO. 50-358, CONSTRUCTION PERMIT NO.  
CPPR-88, W.O. 57300, JOB-5590, FILE NO. NRC-1

Gentlemen:

This letter constitutes a supplement to our previous report QA-2231, dated January 25, 1983 concerning the subject report.

CG&E had anticipated that verification of cable grip installation for vertical runs of cable in conduit and risers greater than thirty-five (35) feet would be completed by February 28, 1983. Initial surveillances of the installations identified that the cable grips were installed in accordance with the design, however, design changes per DDC E-8139 require modifications to the as-built condition before inspection to the current design requirements. A Construction Work Authorization Request (CWAR) is being prepared to obtain approval to perform this fix. Completion of required inspections is contingent upon the NRC's approval of the CWAR. A follow-up report will be submitted by May 6, 1983.

We trust the above will be found acceptable as a supplementary response to the subject report.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By

*E. A. Borgmann*  
E. A. BORGMANN  
SENIOR VICE PRESIDENT

8305240016 830520  
PDR ADOCK 05000358  
Q PDR

FKP:jas

cc: NRC Office of Inspection and Enforcement  
Washington, D.C. 20555  
NRC Senior Resident Inspector  
Attn: W. F. Christianson  
Zimmer Project Inspector  
Region III

MAR 3 1983