



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

May 19, 1983

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: LaSalle County Station Unit 2
Status of Installation of Low
Pressure Scram in CRD System
NRC Docket No. 50-374

Reference (a): C. W. Schroeder letter to Director
of Nuclear Reactor Regulation dated
March 18, 1983.

Dear Sir:

Reference (a) discusses the status of Unit 2 completion with respect to the current Unit 1 License NPF-11 license conditions. With respect to License Condition 2.C.(15), Commonwealth Edison Company stated that the same license condition is appropriate for Unit 2, i.e., "Prior to startup after the first refueling outage, the licensee shall install instrumentation for an automatic scram that would shut down the reactor in the event of low control rod drive pump discharge pressure to be activated during a startup and refueling modes only."

During a telecon on May 13, 1983 with Dr. A. Bournia and Mr. Raj Goel of your staff, it was explained that the applicant continues to feel that this is an appropriate time frame for completion. Currently, we have completed the design and ordered the parts required for installation. Per discussions on May 13, 1983, with Commonwealth Edison Project Engineering and Project Construction, not all of the required parts have yet been received. This letter confirms the telecon with Dr. Bournia and Mr. Raj Goel, per their request.

To the best of my knowledge and belief the statements contained herein are true and correct. In some respects these statements are not based on my personal knowledge but upon information furnished by other Commonwealth Edison and contractor employees. Such information has been reviewed in accordance with Company practice and I believe it to be reliable.

8305240111 830519
PDR ADOCK 05000374
A PDR

13001
110

Director of NRR


- 2 -

May 19, 1983

Enclosed for your use are one (1) signed original and forty (40) copies of this letter.

If there are any further questions regarding this matter, please contact this office.

Very truly yours,

A handwritten signature in dark ink, appearing to read "B. Ryback for", is written over the typed name "C. W. Schroeder".

C. W. Schroeder 5/17
Nuclear Licensing Administrator

lm

cc: NRC Resident Inspector - LSCS

6604N