

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001C Low Volume Waste Regenerative Wastes
Solution Discharge Tank

PARAMETER AND PERMIT LIMIT: Total Suspended Solids, 15 mg/l
Total Iron, 1.0 mg/l
Total Copper, 1.0 mg/l

NONCOMPLIANCE, DATE, AND DURATION:

No sampling and analysis, 11APR83 - 17APR83.

CAUSE OF NONCOMPLIANCE:

The discharge of this tank was originally routed to the waste water treatment facility. During the discharge, additional grab samples were taken and it was determined the remainder of the tank could be discharged to the cooling pond based upon the grab sample results of 9 mg/l T.S.S., 0.22 mg/l Fe, and a pH of 7.3 S.U.. Prior to commencing discharge to the cooling pond, the automatic composite sampler was to be set up to obtain the required composite. Due to a personal error, the composite sampler was not properly set up and the composite sample was missed.

CORRECTIVE ACTION:

Shift personnel will be instructed on the proper set-up of the composite sampler, and on the importance of meeting N.P.D.E.S. requirements.

DATE RECOGNIZED AS A VIOLATION:

18APR83

DATE INVESTIGATED:

18APR83

8305240334 830512
PDR ASUCK 05000373
S PDR



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

DmB

May 12, 1983

James G. Keppler
Regional Administration
Director of Regulatory Operations - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Sir:

In accordance with LaSalle County Station Unit 1 Facility Operating License NPF-11, Appendix B, Section 3.2, we are submitting to you a copy of MPDES noncompliances for LaSalle County Nuclear Generating Station Permit No. IL0048151.

G. J. Diederich
Superintendent
LaSalle County Station

GJD/FRL/JDW/sjc

Enclosure

cc: DVR Report

MAY 19 1983

IEJ2



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

April 20, 1983

U.S. Environmental Protection Agency
Region V, Enforcement Division
ATTN: Chief, Compliance Unit
230 South Dearborn Street
Chicago, IL 60604

Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Management Unit
2200 Churchill Road
Springfield, IL 62706

Dear Sir:

Subject: NPDES Noncompliances for LaSalle County Nuclear
Generating Station - Permit No. IL0048151

In accordance with Standard Condition 12, we wish to submit the following notice of noncompliances, which are listed chronologically in the attached table.

If there are any questions, please contact Joe Williams of my staff at (815) 357-6761, extension 201.

C E Sargent

G. J. Diederich
for Station Superintendent

FRL
GJD/FRL/JDW/lrw

cc: Director of Water Quality, Environmental Affairs
Manager, Nuclear Stations Division