

TABLE 3.6-1 (Cont.)

VALVE NUMBER	FUNCTION	MAXIMUM ISOLATION TIME (SEC.)
27. MOV-2890D*	LHSI Pump Discharge to Reactor Coolant System Cold Legs	NA
28. FCV-2160*	Loop Fill Header	NA
29. MOV-2289A*	Charging Line	NA
30. MOV-2867C*	High Head Safety Injection, Boron Injection Tank	NA
31. MOV-2867D*	High Head Safety Injection, Boron Injection Tank	NA
32. MOV-RS-200A*	Casing Cooling to Outside Recirculation Spray Pump	NA
33. MOV-RS-200B*	Casing Cooling to Outside Recirculation Spray Pump	NA
34. MOV-RS-201A*	Casing Cooling to Outside Recirculation Spray Pump	NA
35. MOV-RS-201B*	Casing Cooling to Outside Recirculation Spray Pump	NA
36. TV-HC-208A	Containment Atmosphere Sample Line	NA
37. TV-HC-208B	Containment Atmosphere Sample Line	NA
F. CHECK		
1. 2-CC-194	Component Cooling Water to RHR System and Excess Letdown Heat Exchanger	NA
2. 2-CC-199	Component Cooling Water to RHR System and Excess Letdown Heat Exchanger	NA
3. 2-SI-93	High Head Safety Injection, Boron Injection to RCS	NA
4. 2-CC-302	Component Cooling Water to Containment Air Recirculation Coils	NA
5. 2-CC-289	Component Cooling Water to Containment Air Recirculation Coils	NA