



State of New Jersey
Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

July 12, 1994

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Salem Generating Station Unit Nos. 1 and 2
Docket Nos. 50-272 and 50-311
License Change Request LCR 94-05
Emergency Diesel Generator Hot Restart Test

On April 12, 1994, Public Service Electric and Gas Company submitted the subject amendment to the Nuclear Regulatory Commission. This request would revise the Emergency Diesel Generator hot restart test by separating it from the 24 hour endurance run and from load sequence testing. The proposed changes are consistent with the improved Standard Technical Specifications (NUREG-1431).

The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering reviewed the above amendment in accordance with the requirements of 10CFR50.91(b) and has no comments.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent Tosch, Manager
Bureau of Nuclear Engineering

100000

9407190320 940712
PDR ADDCK 05000272
P PDR

New Jersey is an Equal Opportunity Employer
Recycled Paper

ADD 1/0

c: Acting Assistant Director McMahon
Radiation Protection Programs
N.J. DEPE

J. Stone
NRC Project Manager

D. Chawaga
NRC Region I State Liaison

C. Marschall
Artificial Island Senior Resident Inspector

F. Thomson
Manager, Licensing and Regulation
PSE&G