



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 17, 1983

JAMES P. McGAUGHY, JR.  
VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-002/1 -  
Update Report - Smoke  
Detectors Covered to  
Perform Planned Maintenance  
Activities  
AECM-83/0280

This is an update to a previous report submitted on March 16, 1983. The event for which the report was submitted occurred on February 1, 1983, when smoke detectors on elevation 119 feet of the Auxiliary Building were covered in order to perform a planned maintenance activity. An hourly fire watch was established in accordance with Technical Specification 3.3.7.9 and the event was reported pursuant to Technical Specification 6.9.2.

The work was completed and the detectors were restored to service on May 9, 1983. The event had no affect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

*J.P. McGaughy*  
For J.P. McGaughy

JPM:sap

cc: Mr. J. B. Richard  
Mr. R. B. McGehee

Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

OFFICIAL COPY

IE 22

Member Middle South Utilities System

8305250405 830517  
PDR ADDCK 05000416  
PDR  
S