

REGION II
ATLANTA, GEORGIA

83 MAY 23 AIO: 35



May 19, 1983
L-83-311

Mr. James P. O'Reilly
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: St. Lucie Unit 2
Docket No. 50-389, 10 CFR 50.55(e), 83-005
Diesel Generator Start Relay Deficiency

This letter is being forwarded to clarify the final report filed by Florida Power and Light Company on April 18, 1983. The report stated that additional indication would be installed in the Control Room to provide plant operators indication when the Diesel Generators are in test. Additional indication has been provided, but to indicate to the Control Room when the Master Control Switch, located in the Diesel Generator Building, is in the STOP position. This annunciator installation was authorized by the same Design Change Notification (DCN-513.2688) that was issued to correct the Start Relay Deficiency, but was not related to that modification.

No additional annunciation is necessary for the Start Relay Deficiency, and all modifications to the Diesel Generator Control Circuitry have been satisfactorily completed.

All pertinent documentation regarding this concern will be maintained at the Site and will be available for your inspection.

Very truly yours,

A handwritten signature in dark ink, appearing to read "Robert E. Uhrig". The signature is fluid and cursive, written over the printed name.

Robert E. Uhrig
Vice President
Advanced Systems and Technology

REU/RJS/cab

OFFICIAL COPY

IE 27

8305250416 830519
PDR ADOCK 05000389
S PDR