



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 17, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-031/0 - Fire
Doors Blocked Open to Allow
Routing of Air Hose
AECM-83/0287

On April 15, 1983, fire doors OC502, OC503, OC708, and OC710 were blocked open to allow the routing of an air hose into the adjacent rooms. The air hose was used to perform a planned maintenance activity (penetration sealant work). This resulted in entrance into the Action Statement of Technical Specification 3.7.7. An hourly fire watch was initiated and maintained for the duration of the event, and the doors were then closed and restored to operation.

The doors were blocked open for 21 days, exceeding the 7 day time limit imposed by Technical Specification 3.7.7, hence, this is submitted as a Special Report pursuant to Technical Specification 6.9.2. The event had no affect on the health and safety of the public and did not constitute a threat to plant safety. This is submitted as a final report.

Yours truly,

J. P. McGaughy
for J. P. McGaughy

JPM:sap

cc: (See Next Page)

8305250434 830517
PDR ADOCK 05000416
S PDR

83 MAY 23 AIO: 33

REGION II
ATLANTA, GEORGIA

OFFICIAL COPY

16 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0287

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. E. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555