

LICENSEE EVENT REPORT

Unit 1

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | T | N | S | N | P | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CONT
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 2 | 7 | 7 | 0 | 2 | 0 | 7 | 8 | 1 | 8 | 0 | 2 | 1 | 6 | 8 | 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | With Unit 1 in Mode 5 and the Auxiliary Building Gas Treatment System (ABGTS) train
03 | "B" fan discharging through the shield building exhaust vent, an operator observed
04 | that the radiation monitor for that exhaust path (2-RM-90-100) was inoperable. The
05 | plant immediately implemented action statements 42 and 44 of limiting condition for
06 | operation 3.3.3.10 and initial samples indicated no iodine or particulate release
07 | and less than 10% of the allowable release for noble gases. There was no effect upon
08 | public health or safety. No previous occurrences.

09 | SYSTEM CODE | M | C | 11 | CAUSE CODE | A | 12 | CAUSE SUBCODE | X | 13 | COMPONENT CODE | Z | Z | Z | Z | Z | Z | 14 | COMP SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16
17 | LER/RO REPORT NUMBER | 8 | 1 | 18 | EVENT YEAR | 8 | 1 | 19 | SEQUENTIAL REPORT NO. | 0 | 2 | 0 | 20 | OCCURRENCE CODE | 0 | 3 | 21 | REPORT TYPE | X | 22 | REVISION NO. | 1 | 23
 ACTION TAKEN | Z | 24 | FUTURE ACTION | Z | 25 | EFFECT ON PLANT | Z | 26 | SHUTDOWN METHOD | Z | 27 | HOURS | 0 | 0 | 0 | 0 | 28 | ATTACHMENT SUBMITTED | N | 29 | NPSD 4 FORM SUB. | N | 30 | PRIME COMP. SUPPLIER | Z | 31 | COMPONENT MANUFACTURER | Z | 9 | 9 | 9 | 32

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | When the 480-V board that supplies 2-RM-90-100 was deenergized Operations was aware
11 | that the radiation monitor 2-RM-90-100 was inoperable. Subsequently the ABGTS fan was
12 | inadvertently turned on causing entry into LCO 3.3.3.10. Procedures used to deenergize
13 | vital boards reference appropriate drawings which indicate equipment that is affected.
14 | No corrective action is applicable.

15 | FACILITY STATUS | G | 28 | % POWER | 0 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator observation | 32

16 | ACTIVITY CONTENT | G | 33 | RELEASED OF RELEASE | N | 34 | AMOUNT OF ACTIVITY | 1.065 E-5 uCi total | 35 | LOCATION OF RELEASE | Shield building exhaust vent | 36

17 | PERSONNEL EXPOSURES | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39

18 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41

19 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | TYPE | NA | 43

20 | PUBLICITY | N | 44 | ISSUED | 8203080516 820216
 PDR ADOCK 05000327
 S PDR

Name of Preparer A. M. Carver /M. R. Hardine

Phone (615) 842-8317

NRC USE ONLY