

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6
---	---	---	---	---	---

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	D	C	C	N	1	2	0	0	-	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4		5
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	--	---

7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0	L	6	0	5	0	0	0	3	1	7	7	0	1	2	9	8	2	8	0	2	2	6	8	2	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (19)

0 2 | At 0900, during normal operation, discovered that #12 Control Room Air

0 3 | Conditioning (A/C) unit tripped and could not be reset (T.S. 3.7.6.1.b).

0 4 | The unit was repaired and returned to service at 1040. #11 Control Room

0 5 | A/C unit remained operable and Control Room temperature never exceeded

0 6 | 80 degrees F during this event. Repetitive events: none.

0 7 |

0 8 |

0	9	S	G	11	E	12	A	13	C	K	T	B	R	K	14	X	15	Z	16	17	8	2	—	0	0	5	—	0	3	L	—	0	18	F	19	Z	20	Z	21	0	0	0	0	22	N	23	Y	24	A	25	R	3	8	9	26
---	---	---	---	----	---	----	---	----	---	---	---	---	---	---	----	---	----	---	----	----	---	---	---	---	---	---	---	---	---	---	---	---	----	---	----	---	----	---	----	---	---	---	---	----	---	----	---	----	---	----	---	---	---	---	----

7 8 9 10 11 12 13 18 19 20 21 22 23 24 26 27 28 29 30 31 32 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A red indication lamp socket (Rowan #2084-EPRI-L120) on the Control

1 1 | Room A/C Supply Fan motor breaker short circuited causing a control fuse

1 2 | to blow, resulting in the A/C unit breaker trip. The socket was re-

1 3 | placed by a spare. A facility change will be initiated to remove the

1 4 | sockets or replace them with a current limiting type.

1	5	E	28	1	0	0	29	NA	30	A	31	Operator Observation	32
---	---	---	----	---	---	---	----	----	----	---	----	----------------------	----

7 8 9 10 12 13 44 45 46 80

1	6	Z	33	Z	34	NA	35	NA	36
---	---	---	----	---	----	----	----	----	----

7 8 9 10 11 44 45 80

1	7	0	0	0	37	Z	38	NA	39
---	---	---	---	---	----	---	----	----	----

7 8 9 11 12 13 80

1	8	0	0	0	40	NA	41
---	---	---	---	---	----	----	----

7 8 9 11 12 80

1	9	Z	42	NA	43
---	---	---	----	----	----

7 8 9 10 808203080524 820226
PDR ADOCK 05000317
S PDR

NA

NAME OF PREPARER J.S. Lagiewski/L.F. Basso

PHONE: 301-269-4747/4986