

3150-0011
EXPIRES 4-30-82

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE (704) 373-7432

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

REGION II
ATLANTA, GEORGIA

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

May 12, 1983

TELEPHONE
(704) 373-4531

83 MAY 20 10:00


Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Re: McGuire Nuclear Station Unit 2
Docket No. 50-370

Dear Mr. O'Reilly:

Please find attached Reportable Occurrence Report RO-370/83-06. This report concerns T.S. 3.4.9.3, "At least one of the following overpressure protection systems shall be operable: a. two power-operated relief valves (PORVs) with a lift setting of less than or equal to 400 psig...". This incident was considered to be of no significance with respect to the health and safety of the public.

Very truly yours,



Hal B. Tucker

PBN:jfw
Attachment

cc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

OFFICIAL COPY

1022