

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	Z	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5				
7	8	9						14						25						30						57						58	
		LICENSEE CODE						LICENSE NUMBER												LICENSE TYPE						CAT							

CON'T

REPORT SOURCE: 01 L 6 0 5 0 - 0 3 2 4 7 0 1 1 8 8 2 8 0 2 1 2 8 2 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During routine surveillance, it was discovered that suppression chamber water tempera-
0 3 | ture recorder, 2-CAC-TR-778, located on the remote shutdown panel, was showing normal
0 4 | expected indications of temperatures, but was not recording them on the chart recorder.
0 5 | A similar event involving this recorder occurred on 12-7-81 and was reported in LER
0 6 | 2-81-134. This event did not affect the health and safety of the public.
0 7 | Technical Specifications 3.3.5.2, 6.9.1.9b
0 8 |

SYSTEM CODE I C		CAUSE CODE E	CAUSE SUBCODE B	COMPONENT CODE I N S T R U					COMP. SUBCODE R	VALVE SUBCODE Z
11		12	13	14					15	16
9 10		11	12	13 18					19	20
EVENT YEAR 8 2		SEQUENTIAL REPORT NO. 0 1 7	OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0			
21 22		23 26		27 29		30 31		32		
ACTION TAKEN B	FUTURE ACTION G	EFFECT ON PLANT Z	SHUTDOWN METHOD Z	HOURS 0 0 0 0		ATTACHMENT SUBMITTED N	NPRD-4 FORM SUB. Y	PRIME COMP. SUPPLIER N	COMPONENT MANUFACTURER B 4 1 5	
33 34	35 36	37 40	41 42	43 44		45 46		47		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The recorder print head actuation linkage had separated from the print actuation
1 1 | solenoid due to an apparent lack of proper linkage retaining spring tension. The
1 2 | linkage was reattached to the actuation solenoid, retaining spring tension was
1 3 | properly adjusted, and the recorder, Model No. 551, returned to service. Applicable
1 4 | maintenance procedures will be revised to check the recorder linkage adjustment.

7	8	9	FACILITY STATUS [1][5] [E] (28)	% POWER [0][6][6] (29)	OTHER STATUS NA (30)	METHOD OF DISCOVERY [A] (31)	DISCOVERY DESCRIPTION Operator Surveillance (32)	
7	8	9	ACTIVITY CONTENT RELEASED OF RELEASE [1][6] [Z] (33) [Z] (34)	AMOUNT OF ACTIVITY NA (35)		LOCATION OF RELEASE NA (36)		
7	8	9	PERSONNEL EXPOSURES NUMBER [1][7] [0][0][0] (37)	TYPE [Z] (38)	DESCRIPTION NA (39)			
7	8	9	PERSONNEL INJURIES NUMBER [1][8] [0][0][0] (40)	DESCRIPTION NA (41)				
7	8	9	LOSS OF OR DAMAGE TO FACILITY TYPE [1][9] [Z] (42)	DESCRIPTION NA (43)				

PUBLICITY

8203080567 820212
PDR ADCK 05000324
S PDR

NA

M. J. Pastva, Jr.

NRC USE ONLY

(919) 457-9521

PHONE _____