



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 17, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-033/0 - Fire
Rated Penetrations Opened
to Implement Design Change
Packages
AECM-83/0282

Beginning on April 11, 1983, the fire rated penetrations listed on the attached page were opened to implement design change packages. Hourly fire watches were established within one hour and will be maintained for the duration of the planned maintenance activities in accordance with Technical Specification 3.7.7.

The condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The work tasks are expected to be complete by July 30, 1983. This is reported as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)

Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

8305250513 830517
PDR ADOCK 05000416
PDR
S

83 MAY 23 AIO: 33

REGION II
ATLANTA, GEORGIA

IE 22

Beginning on April 11, 1983, the following fire rated penetrations were opened to implement design change packages:

PENETRATIONS

INCIDENT REPORT #

CE-7E	83-04-35
CE-179D	83-04-33
CE-417B	83-04-32
CE-323C	83-04-32
CE-360G	83-04-38
CE-1G	83-04-38
CE-82E	83-04-38
CE-278D	83-04-38
CE-12C	83-04-38
CE-4C	83-04-71
CE-272D	83-04-71
CE-95D	83-04-72
CE-8E	83-04-72
CE-210C	83-04-62
CE-438G	83-04-62
AE-87C	83-04-60
AE-132C	83-04-60

FIRE DAMS

L072/LA35	83-04-44
L064/LA37	83-04-25
L064/LA52	83-04-25
L065/LA54	83-04-25
L067/LA53	83-04-25
L066/LA54	83-04-25
L067/LA57	83-04-25
L094/LA23	83-04-25
L094/LA5	83-04-25
L092/LA5	83-04-25
L091/LA4	83-04-25
L089/LA5	83-04-25
L089/LA1	83-04-25
L090/LA4	83-04-25