

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9					14	15											25	26					30		57	CAT	58
LICENSEE CODE		LICENSE NUMBER										LICENSE TYPE																	

CON'T

0 1 7 8

REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 0 1 2 3 8 2 8 0 2 1 2 8 2 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a routine calibration of containment atmosphere oxygen monitor, CAC-AT-1263-2,  
0 3 | it was determined that the instrument would not calibrate. The redundant oxygen  
0 4 | monitor, CAC-AT-1259-2, was operable while the 1263 was inoperable. This event did  
0 5 | not affect the health and safety of the public.  
0 6 | Technical Specifications 3.3.5.3, 3.6.6.4, 6.9.1.9b  
0 7 |  
0 8 |

0	9	SYSTEM CODE		S	E	11	CAUSE CODE		E	12	CAUSE SUBCODE		A	13	COMPONENT CODE					X	X	X	X	X	X	14	COMP. SUBCODE		Z	15	VALVE SUBCODE		Z	16						
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER												
17		8 2		0 1 6		0 3		L		0		C		X		Z		Z		0 0 0 0		N		Y		N		N 3 0 5												

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | An investigation found the monitor exciter lamp had burned out. The lamp was

1 1 | replaced and the monitor, Model No. F3M3-1AX, was calibrated and restored to service.

1 2 | This is an isolated event; however due to other problems experienced with these

1 3 | monitors, they are scheduled to be replaced during the next refueling outage on

1 4 | each unit.

FACILITY STATUS (28) 1 5 E 7 8 9  
% POWER 0 9 4 (29) 10 11 12  
OTHER STATUS (30) NA 13 44  
METHOD OF DISCOVERY (31) B 45 46  
DISCOVERY DESCRIPTION (32) Preventative Maintenance 47 80

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 NA NA

7 8 9 10 11 44 45 8

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

		LOSS OF OR DAMAGE TO FACILITY		
		TYPE	DESCRIPTION	
1	9	Z	(42) NA	(43)

8203080575 820212  
PDR ADCK 05000325  
S PDR

PURCHASER'S NAME (LAST, FIRST, MIDDLE)  
NA

DATE OF ORDER (MM/YY)  
68

QUANTITY  
69

UNIT PRICE  
80

TOTAL PRICE  
NRC USE ONLY

NRC USE ONLY

NAME OF PREPARER K. H. Poulk

PHONE: (919) 457-9521