

**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521, Fax (603) 474-2987

The Northeast Utilities System

Ted C. Feigenbaum
Senior Vice President &
Chief Nuclear Officer

NYN- 94076

July 15, 1994

United States Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk


- References:
- (a) Facility Operating License No. NPF-86, Docket No. 50-443
 - (b) North Atlantic Letter NYN-93037 dated March 3, 1993, "Response to NRC Bulletin No. 90-01, Supplement 1, (TAC M85411)", T. C. Feigenbaum to USNRC
 - (c) Teleconference between Mr. V. L. Rooney and Ms. D. W. Spaulding, USNRC and Mr. J. M. Peschel, North Atlantic, on June 24, 1994

Subject: Response to Request for Additional Information (TAC M85411)

Gentlemen:

North Atlantic Energy Service Corporation (North Atlantic) provides in the Enclosure the additional information requested by the NRC Staff [Reference (c)]. Should you require any additional information regarding this matter please contact Mr. James M. Peschel, Regulatory Compliance Manager, at (603) 474-9521, extension 3772.

Very truly yours,



Ted C. Feigenbaum

TCF:JMP/sm

Enclosure

9407220096 940715
PDR ADDCK 05000443
Q PDR

JE39

United States Nuclear Regulatory Commission
Attention: Document Control Desk

July 15, 1994
Page two

cc: Mr. Thomas T. Martin
Regional Administrator
United States Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Antone C. Cerne
NRC Senior Resident Inspector
P.O. Box 1149
Seabrook, NH 03874

North Atlantic
July 15, 1994

ENCLOSURE 1 TO NYN-94076

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION
NRC BULLETIN 90-01, SUPPLEMENT 1

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION NRC BULLETIN 90-01, SUPPLEMENT 1

NRC Question

The response to Bulletin 90-01, Supplement 1, does not specify the frequency of the enhanced surveillances for items addressed in the response to NRC-requested actions 1e and 1f. Please provide the frequencies for the surveillance of these transmitters.

North Atlantic Response

As stated in the response to Bulletin 90-01, Supplement 1, NRC-requested Actions 1e and 1f, North Atlantic does not currently plan to exclude from the enhanced surveillance program, any transmitters in the categories described by NRC-requested actions 1e and 1f. North Atlantic currently performs the preventive actions of the enhanced surveillance program at least once every refueling cycle, with a maximum interval not exceeding 24 months, for transmitters that are in the categories described by NRC-requested actions 1e and 1f. This is the same surveillance frequency that North Atlantic applies to the transmitters in the category described by NRC-requested action 1c.