

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5				
7	8	LICENSEE CODE						14	LICENSE NUMBER										25	LICENSE TYPE						30	CAT				58

CON'T

0 1
7 8

REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 2 1 8 8 2 8 0 2 2 4 8 2 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During plant operation while performing a whole-core LPRM calibration and base distri-
0 3 | bution using the TIP System, the isolating function of "A" TIP guide tube primary
0 4 | containment isolation ball valve became inoperable because the TIP machine probe would
0 5 | not fully retract from the core. At the time of the event, the "A" TIP manual
0 6 | isolation shear valve was operable. This event did not affect the health and safety
0 7 | of the public.

08 Technical Specifications 3.6.3, 6.9.1.9b 80

0 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
7	8	S	D	E	X	V	A	L	V	E	X	A	D				
		9	10	11	12	13	14				15	16					
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17	8	2	0		2	2	0	3	L	0							
21	22	23		24	25	26	27	28	29	30	31	32					
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
X	X	Z	Z	0	0	0	N	Y	N	G	0	8	0	0			
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The "A" TIP probe was manually retracted and the "A" TIP guide tube ball valve
1 1 operability was re-established within 1 hour and 35 minutes of the event. During the
1 2 scheduled 1982 refueling outage, an investigation of "A" TIP probe retraction problem
1 3 will be performed. A supplement to this report explaining the problem cause and any
1 4 required corrective actions will then be submitted.

FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		
1	5	E	0	6	9	NA	A	Operational Event			
7	8	9	10	11	12	13	14	15	16	17	
ACTIVITY RELEASED		CONTENT OF RELEASE			AMOUNT OF ACTIVITY		LOCATION OF RELEASE				
1	6	Z	Z	NA	NA						
7	8	9	10	11	12	13	14	15	16	17	
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	Z	NA					
7	8	9	10	11	12	13	14	15	16	17	
PERSONNEL INJURIES		NUMBER		DESCRIPTION							
1	8	0	0	0	NA						
7	8	9	10	11	12	13	14	15	16	17	
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION							
1	9	Z	NA								
7	8	9	10	11	12	13	14	15	16	17	

8203080582 820224
PDR ADCK 05000324
S PDR

NRC USE ONLY

NA

68 68

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: (919) 457-9521