NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYJAF1 (2) | 00-0000-000 (3) | 41111 (4) | (5)
LICENSEE CODE (9–14) | LICENSE NUMBER (15–25) | LICENSE TYPE (26–30) | CAT (57–58)

CON'T
01 | REPORT SOURCE L (6) | 05000333 (7) | 032282 (8) | 041682 (9)
DOCKET NUMBER (61–68) | EVENT DATE (69–74) | REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation, while conducting surveillance to satisfy TS Table 4.2-2,
03 Reactor Low Pressure Permissive Switch 02-3-PS-52A was found set at 446 PSIG
04 compared to a TS Table 3.2-2 limit of equal to or greater than 450 PSIG.
05 Redundant pressure switches 02-3-PS-52B, C and D were set properly and would
06 have initiated the low pressure permissive at the proper pressure. No
07 significant hazard existed.
08

09 SYSTEM CODE SF (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE S (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 | — | SEQUENTIAL REPORT NO. 014 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER B069 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Instrument drift is believed to be the cause. The pressure switch was immediately
11 adjusted to within TS limits and surveillance has been increased to weekly until
12 stability has been demonstrated.
13
14

15 FACILITY STATUS E (28) | % POWER 092 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

8204270224

NRC USE ONLY

W. Verne Childs (315) 342-3840 X207