

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

16 April 1982



Mr. Ronald C. Haynes, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA. 19406

Docket No. 50-317
License No. DPR-53

SUBJECT: LER 82-19, Unit 1

Dear Mr. Haynes:

This letter is to confirm our verbal notification of your Mr. Ralph Architzel of the discovery that manual valves in the hydrogen sampling line were closed prohibiting operation of the hydrogen analyzers.

At 1830 on 4-15-82 with Unit 1 in Mode 1 it was discovered that the manual isolation valves inside containment for the six hydrogen sample points were shut, thus rendering the hydrogen analyzer inoperable (T.S. 3.6.5.1). The valves were immediately opened, terminating the event. The redundant hydrogen analyzer was out of service for modifications relating to TMI Action Plan Item II.F.1.6.

A complete description of the events leading to this discovery and any further corrective action will be addressed in a follow-up report.

Very truly yours,

L. B. Russell
for L. B. Russell
Plant Superintendent

LBR:fld

cc: J. A. Tiernan
Director, Office of Management
Information & Program Control
G. S. Pavis

R. M. Douglass
R. E. Architzel
L. B. Russell

8204270272

S

1E29
5/
10