



SHIELDS L. DALTROFF  
VICE PRESIDENT  
ELECTRIC PRODUCTION

## PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-5001



April 22, 1982

Re: Docket Nos. 50-277  
50-278

Mr. Darrel G. Eisenhut, Director  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: Minimum Staffing Requirements for Peach  
Bottom Atomic Power Station

Dear Mr. Eisenhut:

This letter provides confirmation that the Peach Bottom staffing for operating shift personnel meets the requirements of Table III.A.1.2-1 presented in generic letter 81-10, D. G. Eisenhut to All Licensees of Operating Plants, dated February 18, 1981. This confirmation was requested in a March 29, 1982 telephone call from Mr. Robert DeFayette who is reviewing a previous submittal on minimum staffing for emergency operations (J. W. Gallagher to D. G. Eisenhut, dated April 3, 1981).

Table III A.1.2-1 in generic letter 81-10 requires the operating shift for the unit in the emergency condition to consist of at least one shift supervisor (SRO), one shift foreman (SRO), two control room operators, and two auxiliary operators. A footnote to Table III A.1.2-1 requires additional shift personnel for the unaffected unit consisting of at least one shift foreman, one control room operator, and one auxiliary

8204270380

A001  
S/10

operator except that units sharing a control room may share a shift foreman.

The Peach Bottom operating shift, as specified in figure 6.2-2 of Appendix A to the Peach Bottom Technical Specification, provides sufficient personnel to meet both of these requirements. The control room is shared by both units, and consequently the Peach Bottom shift foreman is also shared.

Should you have any questions regarding this matter, please do not hesitate to contact us.

Sincerely yours

A handwritten signature in cursive script, appearing to read "Sh. L. G. Eisenhut", is written in dark ink.