

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

April 16, 1982

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Ms. Adensam:

In the Matter of
Tennessee Valley Authority

) Docket Nos. 50-327
) 50-328

Enclosed is our response to D. G. Eisenhower's March 17, 1982 letter to All Licensees of Operating Power Reactors regarding Post-TMI Requirements (Generic Letter No. 82-05). The enclosure provides a response to each of the items listed in Enclosure 1 to the March 17, 1982 letter from D. G. Eisenhower.

If you have any questions concerning this matter, please get in touch with J. E. Wills at FTS 858-2683.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills

L. M. Mills, Manager
Nuclear Regulation and Safety

Sworn to and subscribed before me
this 16th day of April 1982

Paulette H. White

Notary Public

My Commission Expires 9-5-84

Enclosure

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



Boa1
s
11

8204270415

p

ENCLOSURE

RESPONSE TO D. G. EISENHUT'S MARCH 19, 1981 LETTER TO H. G. PARRIS
POST-TMI REQUIREMENTS (NUREG-0737)
SEQUOYAH NUCLEAR PLANT

I.A.3.1 - Simulator Exams

This item is complete. TVA's simulator exam policy has been in place before this item was required.

II.B.2 - Plant Shielding

This item is complete as documented by the December 19, 1980 L. M. Mills to A. Schwencer letter.

II.B.4 - Training for Mitigating Core Damage

This item is complete as documented by the May 5, 1981 L. M. Mills to A. Schwencer letter.

II.E.1.2 - Auxiliary Feedwater Initiation and Flow Indication

This item is complete as documented by the December 19, 1980 L. M. Mills to A. Schwencer letter.

II.E.4.2 - Containment Isolation Dependability

This item is complete. Part 5 was documented by the January 7, 1981 L. M. Mills to A. Schwencer letter. Part 7 was documented in TVA's NUREG-0578 response transmitted by the July 11, 1980 L. M. Mills to A. Schwencer letter.

II.K.2.10 - Safety-Grade Trip

This item is not applicable to Sequoyah.

II.K.3.15 - Isolation of HPCI and LPCI Modification

This item is not applicable to Sequoyah.

II.K.3.19 - Interlock on Recirculation Pump

This item is not applicable to Sequoyah.

II.K.3.22 - RCIC Suction

This item is not applicable to Sequoyah.

II.K.3.24 - Space Cooling for HPCI/RCIC

This item is not applicable to Sequoyah.

II.K.3.27 - Common Reference Level

This item is not applicable to Sequoyah.

For items II.B.3, II.F.1.1, 2, 3, 4, 5, and 6, TVA is presently required to have these completed no later than startup following the first refueling outage. We are in the process of reevaluating our capability to perform all required and necessary modifications within the required timeframe. By June 15, 1982, we expect to submit a new integrated schedule on all outstanding commitments which will address these items in more detail.